PANELBOARD SCHEDULE — C4BA

Panel C4BA
Service 3 Phase 4 Wire
☐ 208Y/120V
☒ 480Y/277V
Main Bkr. — A — P
Lugs Only 200 A
13966 AIC Minimum
☒ Surface mounted panel
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING ØA	LIGHTING ØB	LIGHTING ØC	GEN. RECEPT. ØA	GEN. RECEPT. ØB	GEN. RECEPT. ØC	SPECIAL ØA	SPECIAL ØB	SPECIAL ØC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
ELECTRICAL TOWER/LGT	1	20	1		0.47									20	1		1	SPARE
ELCTRICAL ROOM DA/LGT	3	20	1			1.0								20	1		4	SPARE
SPARE	5	20	1											20	1		6	SPARE
SPARE	7	20	1												1		8	SPACE ONLY
SPARE	9	20	1												1		10	SPACE ONLY
SPARE	11	20	1												1		12	SPACE ONLY
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.47	1.0	0	0	0	0	0	0	0					

PANELBOARD SCHEDULE — C4BB

Panel C4BB
Service 3 Phase 4 Wire
☐ 208Y/120V
☒ 480Y/277V
Main Bkr. — A — P
Lugs Only 200 A
11222 AIC Minimum
☒ Surface mounted panel
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING ØA	LIGHTING ØB	LIGHTING ØC	GEN. RECEPT. ØA	GEN. RECEPT. ØB	GEN. RECEPT. ØC	SPECIAL ØA	SPECIAL ØB	SPECIAL ØC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
ELECTRICAL TOWER/LGT	1	20	1		0.47									20	1		7	SPARE
SPARE	3	20	1											20	1		4	SPARE
SPARE	5	20	1											20	1		6	SPARE
SPACE ONLY	7		1												1		8	SPACE ONLY
SPACE ONLY	9		1												1		10	SPACE ONLY
SPACE ONLY	11		1												1		12	SPACE ONLY
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.47	0	0	0	0	0	0	0	0					

PANELBOARD SCHEDULE — C41A

Panel C41A
Service 3 Phase 4 Wire
☐ 208Y/120V
☒ 480Y/277V
Main Bkr. — A — P
Lugs Only 200 A
13908 AIC Minimum
☒ Surface mounted panel
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING ØA	LIGHTING ØB	LIGHTING ØC	GEN. RECEPT. ØA	GEN. RECEPT. ØB	GEN. RECEPT. ØC	SPECIAL ØA	SPECIAL ØB	SPECIAL ØC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
ELECTRICAL TOWER/LGTS	1	20	1		0.47									20	1		1	SPARE
0123/LGTS	3	20	1			0.47								20	1		4	SPARE
SPARE	5	20	1											20	1		6	SPARE
SPARE	7	20	1												1		8	SPACE ONLY
SPARE	9	20	1												1		10	SPACE ONLY
SPARE	11	20	1												1		12	SPACE ONLY
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.47	0.47	0	0	0	0	0	0	0					

PANELBOARD SCHEDULE — C41B

Panel C41B
Service — Phase — Wire
☐ 208Y/120V
☒ 480Y/277V
Main Bkr. — A — P
Lugs Only 200 A
10819 AIC Minimum
☒ Surface mounted panel
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING ØA	LIGHTING ØB	LIGHTING ØC	GEN. RECEPT. ØA	GEN. RECEPT. ØB	GEN. RECEPT. ØC	SPECIAL ØA	SPECIAL ØB	SPECIAL ØC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
ELECTRICAL TOWER/LGTS	1	20	1		0.47									20	1		2	SPARE
SPARE	3	20	1											20	1		4	SPARE
SPARE	5	20	1											20	1		6	SPARE
SPACE ONLY	7		1												1		8	SPACE ONLY
SPACE ONLY	9		1												1		10	SPACE ONLY
SPACE ONLY	11		1												1		12	SPACE ONLY
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.47	0	0	0	0	0	0	0	0					

PANELBOARD SCHEDULE — C41C

Panel C41C
Service — Phase — Wire
☐ 208Y/120V
☒ 480Y/277V
Main Bkr. — A — P
Lugs Only 200 A
3034 AIC Minimum
☒ Surface mounted panel
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING ØA	LIGHTING ØB	LIGHTING ØC	GEN. RECEPT. ØA	GEN. RECEPT. ØB	GEN. RECEPT. ØC	SPECIAL ØA	SPECIAL ØB	SPECIAL ØC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
ELECTRICAL TOWER/LCI	1	20			0.47									20	1		2	SPARE
SPARE	3	20	1											20	1		4	SPARE
SPARE	5	20	1											20	1		6	SPARE
SPACE ONLY	7		1												1		8	SPACE ONLY
SPACE ONLY	9		1												1		10	SPACE ONLY
SPACE ONLY	11		1												1		12	SPACE ONLY
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.47	0	0	0	0	0	0	0	0					

PANELBOARD SCHEDULE — C42A

Panel C42A
Service 3 Phase 4 Wire
☒ 208Y/120V
☐ 480Y/277V
Main Bkr. — A — P
Lugs Only 200 A
13622 AIC Minimum
☒ Surface mounted panel
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING ØA	LIGHTING ØB	LIGHTING ØC	GEN. RECEPT. ØA	GEN. RECEPT. ØB	GEN. RECEPT. ØC	SPECIAL ØA	SPECIAL ØB	SPECIAL ØC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
A236, A246, A253/LGI	1	20			2.55									20	1		2	A241,43,44,45,56/BL
0218, 0219, 0221	3	20	1		5.1	2.40								20	1		4	A212,13,23,25/BL
ELECTRICAL TOWER/LGTS	5	20	1			5.1	1.0							20	1		6	A208,19,20,21,30/BL
SPARE	7	20	1				4.6							20	1		8	SPARE
SPARE	9	20	1											20	1		10	SPARE
SPARE	11	20	1											20	1		12	SPARE
SPARE	13	20	1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					7.65	7.5	5.6	0	0	0	0	0	0					

PANELBOARD SCHEDULE — C42B

Panel C42B
Service 3 Phase 4 Wire
☐ 208Y/120V
☒ 480Y/277V
Main Bkr. — A — P
Lugs Only 200 A
10926 AIC Minimum
☒ Surface mounted panel
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING ØA	LIGHTING ØB	LIGHTING ØC	GEN. RECEPT. ØA	GEN. RECEPT. ØB	GEN. RECEPT. ØC	SPECIAL ØA	SPECIAL ØB	SPECIAL ØC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
B206,07,15,16/BL ELECTRICAL TOWER/LGTS	1	20	1		4.6									20	1		2	B219,220,29/BL
B225,26,36/BL	3	20	1		3.7	5.5								20	1		4	B204,12,13/BL
B230,37,42,43/BL	5	20	1			3.7	4.6							20	1		6	0226/BL
SPARE	7	20	1				1.4							20	1		8	SPARE
SPARE	9	20	1											20	1		10	SPARE
SPARE	11	20	1											20	1		12	SPARE
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					8.3	9.2	6.0	0	0	0	0	0	0					

PANELBOARD SCHEDULE — C42C

Panel C42C
Service 3 Phase 4 Wire
☐ 208Y/120V
☒ 480Y/277V
Main Bkr. — A — P
Lugs Only 200 A
3097 AIC Minimum
☒ Surface mounted panel
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING ØA	LIGHTING ØB	LIGHTING ØC	GEN. RECEPT. ØA	GEN. RECEPT. ØB	GEN. RECEPT. ØC	SPECIAL ØA	SPECIAL ØB	SPECIAL ØC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
C245/LGT	1	20	1		0.5									20	1		2	0236,40/BL
C230,37/BL ELECTRICAL TOWER/LGBS	3	20	1		2.3	3.2								20	1		4	SPARE
SPARE	5	20	1				4.2							20	1		6	SPARE
SPARE	7	20	1											20	1		8	SPARE
SPARE	9	20	1												1		10	SPACE ONLY
SPACE ONLY	11		1												1		12	SPACE ONLY
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					2.8	3.2	4.2	0	0	0	0	0	0					

C4BA C41C
C4BB C42A
C41A C42B
C41B C42C

SEAL AREA

REVISION DESCRIPTION | DWG OR DR. | DATE | SATISFACTORY TO | DATE

DESIGN BY: SWA DRAWN BY: CBN CHK BY: RES APPROVED:

NAVAL FACILITIES ENGINEERING COMMAND
DEPARTMENT OF THE NAVY
NAVY PUBLIC WORKS CENTER, JACKSONVILLE, FL
U.S. NAVAL STATION ROOSEVELT ROADS, P.R.
REPAIRS TO NAVAL HOSPITAL
480V PANELBOARDS – CRITICAL BRANCH
CONTR. CONTR NO. XXXXX | MANFAC DRWG NO. XXXXX | PWC DWG NO. XXXXX

SHERLOCK, SMITH & ADAMS, INC.
ARCHITECTS – ENGINEERS
MONTGOMERY, ALABAMA

U.S. NAVAL STATION ROOSEVELT ROADS, P.R.
REPAIRS TO NAVAL HOSPITAL
480V PANELBOARDS – CRITICAL BRANCH

CONSTR. CONTR NO. XXXXX | SPECIFICATION NO. XXXXX | MANFAC DRWG. NO. XXXXX | TF NO. XXXXX | SHEET ? OF ??

PLATE NO. EP9-20

PANELBOARD SCHEDULE

Panel ICU
Service 3 Phase 4 Wire
☐ 208Y/120V
☒ 480Y/277V
Main Bkr. - A - P
Lugs Only 200 A
6249 AIC Minimum
☒ Surface mounted panel
Remarks
-

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	AMPS PER PHASE LIGHTING GA	LIGHTING GB	LIGHTING GC	GEN. RECEPT. GA	GEN. RECEPT. GB	GEN. RECEPT. GC	SPECIAL GA	SPECIAL GB	SPECIAL GC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
C233/LGT	1	20	1		1			-			-			20	1		1	SPARE
C233/LGT	3	20	1		-	2.4		-			-			20	1		4	SPARE
C235,C238/LGT	5	20	1				0.93	-			-			20	1		6	SPARE
SPARE	7	20	1		-			-			-			-	1		8	SPACE ONLY
SPARE	9	20	1		-			-			-			-	1		10	SPACE ONLY
SPARE	11	20	1		-			-			-			-	1		12	SPACE ONLY
SPACE ONLY	13	-	1		-			-			-			-	1		14	SPACE ONLY
SPACE ONLY	15	-	1		-			-			-			-	1		16	SPACE ONLY
SPACE ONLY	17	-	1		-			-			-			-	1		18	SPACE ONLY
SPACE ONLY	19	-	1		-			-			-			-	1		20	SPACE ONLY
SPACE ONLY	21	-	1		-			-			-			-	1		22	SPACE ONLY
SPACE ONLY	23	-	1		-			-			-			-	1		24	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					4.7	2.4	0.93	0	0	0	0	0	0					

PANELBOARD SCHEDULE

Panel OR
Service 3 Phase 4 Wire
☐ 208Y/120V
☒ 480Y/277V
Main Bkr. - A - P
Lugs Only 200 A
7679 AIC Minimum
☒ Surface mounted panel
Remarks
-

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	AMPS PER PHASE LIGHTING GA	LIGHTING GB	LIGHTING GC	GEN. RECEPT. GA	GEN. RECEPT. GB	GEN. RECEPT. GC	SPECIAL GA	SPECIAL GB	SPECIAL GC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
C221	1	20	1		1.4			-			-			20	1		1	OPERATING ROOM C222
OPERATING ROOM C224/LGT	3	20	1		13.9	13.9		-			-			20	1		4	OPERATING ROOM C222
OPERATING ROOM C224/LGT	5	20	1			13.9		-			-			20	1		6	SPARE
OPERATING ROOM C224/LGT	7	20	1		13.9			-			-			20	1		8	SPARE
SPARE	9	20	1		-			-			-			20	1		10	SPARE
OPERATING ROOM C208/LGT	11	20	1		-	13.9		-			-			20	1		12	SPARE
SPACE ONLY	13	-	1		-			-			-			20	1		14	SPARE
SPACE ONLY	15	-	1		-			-			-			-	1		16	SPACE ONLY
SPACE ONLY	17	-	1		-			-			-			-	1		18	SPACE ONLY
SPACE ONLY	19	-	1		-			-			-			-	1		20	SPACE ONLY
SPACE ONLY	21	-	1		-			-			-			-	1		22	SPACE ONLY
SPACE ONLY	23	-	1		-			-			-			-	1		24	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					29.2	27.8	27.8							-	-	-	-	-

SWITCHBOARD SCHEDULE

Panel NUR
Service - Phase - Wire
☐ 208Y/120V
☒ 480Y/277V
Main Bkr. - A - P
Lugs Only 200 A
- AIC Minimum
☒ Surface mounted panel
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	AMPS PER PHASE LIGHTING GA	LIGHTING GB	LIGHTING GC	GEN. RECEPT. GA	GEN. RECEPT. GB	GEN. RECEPT. GC	SPECIAL GA	SPECIAL GB	SPECIAL GC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
SPARE	1	20	1		-			-			-			20	1		1	SPARE
SPARE	3	20	1			-			-			-		20	1		4	SPARE
SPARE	5	20	1				-			-			-	20	1		6	SPARE
SPACE ONLY	7	-	1		-			-			-			-	1		8	SPACE ONLY
SPACE ONLY	9	-	1			-			-			-		-	1		10	SPACE ONLY
SPACE ONLY	11	-	1				-			-			-	-	1		12	SPACE ONLY
SPACE ONLY	13	-	1		-			-			-			-	1		14	SPACE ONLY
SPACE ONLY	15	-	1			-			-			-		-	1		16	SPACE ONLY
SPACE ONLY	17	-	1				-			-			-	-	1		18	SPACE ONLY
SPACE ONLY	19	-	1		-			-			-			-	1		20	SPACE ONLY
SPACE ONLY	21	-	1			-			-			-		-	1		22	SPACE ONLY
SPACE ONLY	23	-	1				-			-			-	-	1		24	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					-	-	-	-	-	-	-	-	-					

SWITCHBOARD SCHEDULE

Panel ER
Service - Phase - Wire
☐ 208Y/120V
☒ 480Y/277V
Main Bkr. - A - P
Lugs Only 200 A
- AIC Minimum
☒ Surface mounted panel
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	AMPS PER PHASE LIGHTING GA	LIGHTING GB	LIGHTING GC	GEN. RECEPT. GA	GEN. RECEPT. GB	GEN. RECEPT. GC	SPECIAL GA	SPECIAL GB	SPECIAL GC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
SPARE	1	20	1		-			-			-			20	1		1	SPARE
SPARE	3	20	1			-			-			-		20	1		4	SPARE
SPARE	5	20	1				-			-			-	20	1		6	SPARE
SPACE ONLY	7	-	1		-			-			-			-	1		8	SPACE ONLY
SPACE ONLY	9	-	1			-			-			-		-	1		10	SPACE ONLY
SPACE ONLY	11	-	1				-			-			-	-	1		12	SPACE ONLY
SPACE ONLY	13	-	1		-			-			-			-	1		14	SPACE ONLY
SPACE ONLY	15	-	1			-			-			-		-	1		16	SPACE ONLY
SPACE ONLY	17	-	1				-			-			-	-	1		18	SPACE ONLY
SPACE ONLY	19	-	1		-			-			-			-	1		20	SPACE ONLY
SPACE ONLY	21	-	1			-			-			-		-	1		22	SPACE ONLY
SPACE ONLY	23	-	1				-			-			-	-	1		24	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					-	-	-	-	-	-	-	-	-					

ICU
OR
NUR
ER

SHERLOCK, SMITH & ADAMS, INC.
ARCHITECTS – ENGINEERS
MONTGOMERY, ALABAMA

U.S. NAVAL STATION RODSEVELT ROADS, P.R.
REPAIRS TO NAVAL HOSPITAL
480V PANELBOARDS – CRITICAL BRANCH

CONSTR CONTR NO	SPECIFICATION NO	MANFAC DWNG NO	TF NO XXXXX
XXXXX	XXXXX	XXXXX	SHEET ? OF ??

PLATE NO
EP9-21

PWC # XXXXX

DEPARTMENT OF THE NAVY
NAVY PUBLIC WORKS CENTER, JACKSONVILLE, FL
NAVAL FACILITIES ENGINEERING COMMAND
U.S. NAVAL STATION RODSEVELT ROADS, P.R.
REPAIRS TO NAVAL HOSPITAL
480V PANELBOARDS – CRITICAL BRANCH

CONSTR CONTR NO XXXXX | MANFAC DWG NO XXXXX | PWC DWG NO XXXXX

DESIGN BY: SWA | DRAWN BY: CBN
CHK BY: RCS | APPROVED

SEAL AREA

DWG. DIV. DIR.: | DATE: | SATISFACTORY TO: | DATE:

DATE	REVISION DESCRIPTION

P:\95-115\F\11\EP921.dwg (96/96) 04/30/96 at 14:39:46 by NF SON B

PANELBOARD SCHEDULE

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING GA	LIGHTING GB	LIGHTING GC	GEN. RECEPT. GA	GEN. RECEPT. GB	GEN. RECEPT. GC	SPECIAL GA	SPECIAL GB	SPECIAL GC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
A01, A02, A03, A04/LGIS	1	20	1		2.03									20	1		2	SUB-BASEMENT/EMT
					1.0													
B01	3	20	1			1.02								20	1		4	STAIRWAY D/LGTS
						1.0												
D07, D05	5	20	1				0.97							20	1		6	FIRE ALARM SYSTEM ALARMS
SPARE	7	20	1										3.0	20	1		8	SPARE
SPARE	9	20	1											20	1		10	SPARE
SPARE	11	20	1											20	1		12	SPARE
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					3.03	4.02	0.97	0	0	0	0	0	3.0					

Panel L4BD
Service 3 Phase 4 Wire
☐ 208Y/120V
☒ 480Y/277V
Main Bkr. - A - P
Lugs Only 100 A
5697 AIC Minimum
☒ Surface mounted panel
Remarks

PANELBOARD SCHEDULE

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING GA	LIGHTING GB	LIGHTING GC	GEN. RECEPT. GA	GEN. RECEPT. GB	GEN. RECEPT. GC	SPECIAL GA	SPECIAL GB	SPECIAL GC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
A101, A102, A104, A105/LGIS	1	20	1		3.53									20	1		2	0104, 0105, 0108/LGI
					2.44													
B101, B102, B102A/LGTS	3	20				2.21								20	1		4	STAIRWAY C/LGTS
C101, C103, C104, C104A/LGI	5	20	1				1.0							20	1		6	SPARE
SPARE	7	20	1											20	1		8	SPARE
SPARE	9	20	1											20	1		10	SPARE
SPARE	11	20	1											20	1		12	SPARE
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					11	2.3	3.0	0	0	0	0	0	0					

Panel L41D
Service 3 Phase 4 Wire
☐ 208Y/120V
☒ 480Y/277V
Main Bkr. - A - P
Lugs Only 100 A
4159 AIC Minimum
☒ Surface mounted panel
Remarks

PANELBOARD SCHEDULE

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING GA	LIGHTING GB	LIGHTING GC	GEN. RECEPT. GA	GEN. RECEPT. GB	GEN. RECEPT. GC	SPECIAL GA	SPECIAL GB	SPECIAL GC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
A201, A202, A203, A206, D205, D203, D202, D206, D204/LGI	1	20	1		6.03									20	1		2	AREA B STEP LGIS
B201, D202, B203, B203D, D204	3	20	1			4.7								20	1		4	AREA A STEP LGIS
C201	5	20	1				1.90							20	1		6	SPARE
SPARE	7	20	1											20	1		8	SPARE
SPARE	9	20	1											20	1		10	SPARE
SPARE	11	20	1											20	1		12	SPARE
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					6.03	4.7	1.9	0	0	0	0	0	0					

Panel L42C
Service 3 Phase 4 Wire
☐ 208Y/120V
☒ 480Y/277V
Main Bkr. - A - P
Lugs Only 100 A
4659 AIC Minimum
☒ Surface mounted panel
Remarks

PANELBOARD SCHEDULE

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING GA	LIGHTING GB	LIGHTING GC	GEN. RECEPT. GA	GEN. RECEPT. GB	GEN. RECEPT. GC	SPECIAL GA	SPECIAL GB	SPECIAL GC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
A0102,A0103,A0104,A0105/LGIS	1	20	1		4.0									20	1		2	SPARE
SPARE	3	20	1											20	1		4	SPARE
SPARE	5	20	1											20	1		6	SPARE
WATER JACKET HEATER - CEN. 1	7	20	3								9.7			20	3		8	WATER JACKET HEATER - GEN. 2
											9.7							
WATER JACKET HEATER - CEN. 7	9											9.7					10	WATER JACKET HEATER - GEN. 2
												9.7						
WATER JACKET HEATER - CEN. 1	11												9.7				12	WATER JACKET HEATER - CEN. 2
													9.7					
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1		0			3.3			8.4			30	3		20	L2G THRU TRANSFORMER 1-LG
SPACE ONLY	21		1			0			3.9			8.4					22	L2C THRU TRANSFORMER 1-LC
SPACE ONLY	23		1				0			4.6			3.1				24	L2C THRU TRANSFORMER 1-LG
TOTAL CONNECTED LOAD (AMPS)					4.0	0	0	3.3	3.9	4.6	27.8	27.8	22.5					

Panel L4G
Service 3 Phase 4 Wire
☐ 208Y/120V
☒ 480Y/277V
Main Bkr. - A - P
Lugs Only 100 A
12927 AIC Minimum
☒ Surface mounted panel
Remarks
-

L4BD
L41D
L42C
L4G

SHERLOCK, SMITH & ADAMS, INC.
ARCHITECTS – ENGINEERS
MONTGOMERY, ALABAMA

U.S. NAVAL STATION ROOSEVELT ROADS, P.R.
REPAIRS TO NAVAL HOSPITAL
480V PANELBOARDS – LIFE SAFETY BRANCH

CONSTR. CONTR NO XXXXX | SPECIFICATION NO XXXXX | NAVFAC DRWG NO XXXXX | FY NO XXXXX | SHEET ? OF ??

PLATE NO
EP9-30

PWC # XXXXX

DEPARTMENT OF THE NAVY
NAVY PUBLIC WORKS CENTER, JACKSONVILLE, FL
NAVAL FACILITIES ENGINEERING COMMAND
U.S. NAVAL STATION ROOSEVELT ROADS, P.R.
REPAIRS TO NAVAL HOSPITAL
480V PANELBOARDS – LIFE SAFETY BRANCH

CONSTR. CONTR. NO XXXXX | NAVFAC DWG. NO. XXXXX | PWC DWG. NO. XXXXX

DESIGN BY: SWA | DRAWN BY: DBN
CHK BY: RCS | APPROVED:

REVISION DESCRIPTION | DATE | ENG. DIV. DIR. | DATE | SATISFACTORY TO: | DATE

SEAL AREA

PANELBOARD SCHEDULE

Panel Q4BD

Service 3 Phase 4 Wire

☐ 208Y/120V

☒ 480Y/277V

Main Bkr. – A – P

Lugs Only 100 A

8681 AIC Minimum

☒ Surface mounted panel

Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
SPARE	1	20	1		–			–			–			20	1		2	SPARE
SPARE	3	20	1		–			–			–			20	1		4	SPARE
SPARE	5	20	1		–			–			–			20	1		6	SPARE
SPACE ONLY	7	–	1		–			–			–			–	1		8	SPACE ONLY
SPACE ONLY	9	–	1		–			–			–			–	1		10	SPACE ONLY
SPACE ONLY	11	–	1		–			–			–			–	1		12	SPACE ONLY
SPACE ONLY	13	–	1		–			–			–			–	1		14	SPACE ONLY
SPACE ONLY	15	–	1		–			–			–			–	1		16	SPACE ONLY
SPACE ONLY	17	–	1		–			–			–			–	1		18	SPACE ONLY
SPACE ONLY	19	–	1		–			–			–			–	1		20	SPACE ONLY
SPACE ONLY	21	–	1		–			–			–			–	1		22	SPACE ONLY
SPACE ONLY	23	–	1		–			–			–			–	1		24	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					

PANELBOARD SCHEDULE

Panel Q41D

Service 3 Phase 4 Wire

☐ 208Y/120V

☒ 480Y/277V

Main Bkr. – A – P

Lugs Only 100 A

4936 AIC Minimum

☒ Surface mounted panel

Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W	CIR. NO.	ROOM NOS / REMARKS
SPARE	1	20	1		–			–			–			20	1		2	SPARE
SPARE	3	20	1		–			–			–			20	1		4	SPARE
SPARE	5	20	1		–			–			–			20	1		6	SPACE ONLY
SPACE ONLY	7	–	1		–			–			–			–	1		8	SPACE ONLY
SPACE ONLY	9	–	1		–			–			–			–	1		10	SPACE ONLY
SPACE ONLY	11	–	1		–			–			–			–	1		12	SPACE ONLY
SPACE ONLY	13	–	1		–			–			–			–	1		14	SPACE ONLY
SPACE ONLY	15	–	1		–			–			–			–	1		16	SPACE ONLY
SPACE ONLY	17	–	1		–			–			–			–	1		18	SPACE ONLY
SPACE ONLY	19	–	1		–			–			–			–	1		20	SPACE ONLY
SPACE ONLY	21	–	1		–			–			–			–	1		22	SPACE ONLY
SPACE ONLY	23	–	1		–			–			–			–	1		24	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					

PANELBOARD SCHEDULE

Panel Q42C

Service 3 Phase 4 Wire

☐ 208Y/120V

☒ 480Y/277V

Main Bkr. – A – P

Lugs Only 100 A

6555 AIC Minimum

☒ Surface mounted panel

Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W	CIR. NO.	ROOM NOS / REMARKS
SPARE	1	20	1		–			–			–			20	1		2	SPARE
SPARE	3	20	1		–			–			–			20	1		4	SPARE
SPARE	5	20	1		–			–			–			20	1		6	SPACE ONLY
SPACE ONLY	7	–	1		–			–			–			–	1		8	SPACE ONLY
SPACE ONLY	9	–	1		–			–			–			–	1		10	SPACE ONLY
SPACE ONLY	11	–	1		–			–			–			–	1		12	SPACE ONLY
SPACE ONLY	13	–	1		–			–			–			–	1		14	SPACE ONLY
SPACE ONLY	15	–	1		–			–			–			–	1		16	SPACE ONLY
SPACE ONLY	17	–	1		–			–			–			–	1		18	SPACE ONLY
SPACE ONLY	19	–	1		–			–			–			–	1		20	SPACE ONLY
SPACE ONLY	21	–	1		–			–			–			–	1		22	SPACE ONLY
SPACE ONLY	23	–	1		–			–			–			–	1		24	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					

Q4BD

Q41D

Q42C

SHERLOCK, SMITH & ADAMS, INC.
ARCHITECTS – ENGINEERS
MONTGOMERY, ALABAMA

U.S. NAVAL STATION ROOSEVELT ROADS, P.R.
REPAIRS TO NAVAL HOSPITAL
480V PANELBOARDS – EQUIPMENT BRANCH

CONTR. CONTR. NO	SPECIFICATION NO	NAVFAC DWG. NO	IF NO XXXXX SHEET ? OF ??
XXXXX	XXXXX	XXXXX	

SEAL AREA

DATE | REVISION DESCRIPTION | DWG. CHK. DATE | DATE | SATISFACTORY TO: | DATE | DESIGN BY: SWA | DRAWN BY: CBM | CHK BY: RLS | APPROVED:

NAVAL FACILITIES ENGINEERING COMMAND
DEPARTMENT OF THE NAVY
NAVY PUBLIC WORKS CENTER, JACKSONVILLE, FL
U.S. NAVAL STATION ROOSEVELT ROADS, P.R.
REPAIRS TO NAVAL HOSPITAL
480V PANELBOARDS – EQUIPMENT BRANCH

NAVFAC DWG. NO XXXXX | PWC DWG. NO XXXXX | PLATE NO

EP9-35

PANELBOARD SCHEDULE

Panel N2BA
Service 3 Phase 4 Wire
☒ 208Y/120V
☐ 480Y/277V
Main Bkr. - A - P
Lugs Only 200 A
5325 AIC Minimum
☒ Surface mounted panel
☒ 200% Neutral Bar
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
D03/LGTS	1	20	1		8.15									20	1		2	SPARE
D04/LGTS	3	20	1			7.5								20	1		4	SPARE
D02/LGTS	5	20	1				15.0							20	1		6	SPARE
SPARE	7	20	1												1		8	SPACE ONLY
SPARE	9	20	1												1		10	SPACE ONLY
SPARE	11	20	1												1		12	SPACE ONLY
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
SPACE ONLY	25		1												1		26	SPACE ONLY
SPACE ONLY	27		1												1		28	SPACE ONLY
SPACE ONLY	29		1												1		30	SPACE ONLY
SPACE ONLY	31		1												1		32	SPACE ONLY
SPACE ONLY	33		1												1		34	SPACE ONLY
SPACE ONLY	35		1												1		36	SPACE ONLY
SPACE ONLY	37		1												1		38	SPACE ONLY
SPACE ONLY	39		1												1		40	SPACE ONLY
SPACE ONLY	41		1												1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					8.8	7.5	15.0	0.0	0.0	0.0	0.0	0.0	0.0					

PANELBOARD SCHEDULE

Panel N2BB
Service 3 Phase 4 Wire
☒ 208Y/120V
☐ 480Y/277V
Main Bkr. - A - P
Lugs Only 200 A
5147 AIC Minimum
☒ Surface mounted panel
☒ 200% Neutral Bar
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
SPARE	1	20	1											20	1		2	SPARE
SPARE	3	20	1											20	1		4	SPARE
SPARE	5	20	1											20	1		6	SPARE
SPACE ONLY	7		1												1		8	SPACE ONLY
SPACE ONLY	9		1												1		10	SPACE ONLY
SPACE ONLY	11		1												1		12	SPACE ONLY
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
SPACE ONLY	25		1												1		26	SPACE ONLY
SPACE ONLY	27		1												1		28	SPACE ONLY
SPACE ONLY	29		1												1		30	SPACE ONLY
SPACE ONLY	31		1												1		32	SPACE ONLY
SPACE ONLY	33		1												1		34	SPACE ONLY
SPACE ONLY	35		1												1		36	SPACE ONLY
SPACE ONLY	37		1												1		38	SPACE ONLY
SPACE ONLY	39		1												1		40	SPACE ONLY
SPACE ONLY	41		1												1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					

PANELBOARD SCHEDULE

Panel N21A
Service 3 Phase 4 Wire
☒ 208Y/120V
☐ 480Y/277V
Main Bkr. - A - P
Lugs Only 200 A
4663 AIC Minimum
☒ Surface mounted panel
☒ 200% Neutral Bar
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
SPARE	1	20	1											20	1		2	SPARE
SPARE	3	20	1											20	1		4	SPARE
SPARE	5	20	1											20	1		6	SPARE
SPACE ONLY	7		1												1		8	SPACE ONLY
SPACE ONLY	9		1												1		10	SPACE ONLY
SPACE ONLY	11		1												1		12	SPACE ONLY
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
SPACE ONLY	25		1												1		26	SPACE ONLY
SPACE ONLY	27		1												1		28	SPACE ONLY
SPACE ONLY	29		1												1		30	SPACE ONLY
SPACE ONLY	31		1												1		32	SPACE ONLY
SPACE ONLY	33		1												1		34	SPACE ONLY
SPACE ONLY	35		1												1		36	SPACE ONLY
SPACE ONLY	37		1												1		38	SPACE ONLY
SPACE ONLY	39		1												1		40	SPACE ONLY
SPACE ONLY	41		1												1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					

PANELBOARD SCHEDULE

Panel N21B
Service 3 Phase 4 Wire
☒ 208Y/120V
☐ 480Y/277V
Main Bkr. - A - P
Lugs Only 200 A
4659 AIC Minimum
☒ Surface mounted panel
☒ 200% Neutral Bar
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
SPARE	1	20	1											20	1		2	SPARE
SPARE	3	20	1											20	1		4	SPARE
SPARE	5	20	1											20	1		6	SPARE
SPACE ONLY	7		1												1		8	SPACE ONLY
SPACE ONLY	9		1												1		10	SPACE ONLY
SPACE ONLY	11		1												1		12	SPACE ONLY
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
SPACE ONLY	25		1												1		26	SPACE ONLY
SPACE ONLY	27		1												1		28	SPACE ONLY
SPACE ONLY	29		1												1		30	SPACE ONLY
SPACE ONLY	31		1												1		32	SPACE ONLY
SPACE ONLY	33		1												1		34	SPACE ONLY
SPACE ONLY	35		1												1		36	SPACE ONLY
SPACE ONLY	37		1												1		38	SPACE ONLY
SPACE ONLY	39		1												1		40	SPACE ONLY
SPACE ONLY	41		1												1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					

PANELBOARD SCHEDULE

Panel N21C
Service 3 Phase 4 Wire
☒ 208Y/120V
☐ 480Y/277V
Main Bkr. - A - P
Lugs Only 200 A
2940 AIC Minimum
☒ Surface mounted panel
☒ 200% Neutral Bar
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
SPARE	1	20	1											20	1		2	SPARE
SPARE	3	20	1											20	1		4	SPARE
SPARE	5	20	1											20	1		6	SPARE
SPACE ONLY	7		1												1		8	SPACE ONLY
SPACE ONLY	9		1												1		10	SPACE ONLY
SPACE ONLY	11		1												1		12	SPACE ONLY
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
SPACE ONLY	25		1												1		26	SPACE ONLY
SPACE ONLY	27		1												1		28	SPACE ONLY
SPACE ONLY	29		1												1		30	SPACE ONLY
SPACE ONLY	31		1												1		32	SPACE ONLY
SPACE ONLY	33		1												1		34	SPACE ONLY
SPACE ONLY	35		1												1		36	SPACE ONLY
SPACE ONLY	37		1												1		38	SPACE ONLY
SPACE ONLY	39		1												1		40	SPACE ONLY
SPACE ONLY	41		1												1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					

N2BA N21B
N2BB N21C
N21A

SHERLOCK, SMITH & ADAMS, INC.
ARCHITECTS – ENGINEERS
MONTGOMERY, ALABAMA

U.S. NAVAL STATION ROOSEVELT ROADS, P.R.
REPAIRS TO NAVAL HOSPITAL
208V PANELBOARDS – NORMAL SYSTEM

CONSTR. CONTR NO XXXXX | SPECIFICATION NO. XXXXX | NAVFAC DRWG. NO. XXXXX | TF NO XXXXX | SHEET 7 OF 77

SEAL AREA

DSN. BY: SWA DRAWN BY: CBN
CHK. BY: RFC APPROVED:

SUBMITTED TO: DATE:
DSN. CH. OKE: DATE:
REVISION DESCRIPTION DATE

NAVAL FACILITIES ENGINEERING COMMAND
DEPARTMENT OF THE NAVY
NAVY PUBLIC WORKS CENTER, JACKSONVILLE, FL
U.S. NAVAL STATION ROOSEVELT ROADS, P.R.
REPAIRS TO NAVAL HOSPITAL
208V PANELBOARDS – NORMAL SYSTEM

CONTR. CONTL. NO. XXXXX | NAVFAC DWG. NO. XXXXX | PWC DWG. NO. XXXXX

PLATE NO
EP9-40

PANELBOARD SCHEDULE

Panel N22A

Service 3 Phase 4 Wire

☒ 208Y/120V

☐ 480Y/277V

Main Bkr. - A - P

Lugs Only 200 A

4579 AIC Minimum

☒ Surface mounted panel

☒ 200% Neutral Bar

Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
D218, D219, D221	1	20	1		4.7									20	1		2	SPARE
SPARE	3	20	1											20	1		4	SPARE
SPARE	5	20	1											20	1		6	SPARE
SPACE ONLY	7		1												1		8	SPACE ONLY
SPACE ONLY	9		1												1		10	SPACE ONLY
SPACE ONLY	11		1												1		12	SPACE ONLY
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
SPACE ONLY	25		1												1		26	SPACE ONLY
SPACE ONLY	27		1												1		28	SPACE ONLY
SPACE ONLY	29		1												1		30	SPACE ONLY
SPACE ONLY	31		1												1		32	SPACE ONLY
SPACE ONLY	33		1												1		34	SPACE ONLY
SPACE ONLY	35		1												1		36	SPACE ONLY
SPACE ONLY	37		1												1		38	SPACE ONLY
SPACE ONLY	39		1												1		40	SPACE ONLY
SPACE ONLY	41		1												1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					4.7	0	0	0	0	0	0	0	0					

PANELBOARD SCHEDULE

Panel N22B

Service 3 Phase 4 Wire

☒ 208Y/120V

☐ 480Y/277V

Main Bkr. - A - P

Lugs Only 200 A

4511 AIC Minimum

☒ Surface mounted panel

☒ 200% Neutral Bar

Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
SPARE	1	20	1											20	1		2	SPARE
SPARE	3	20	1											20	1		4	SPARE
SPARE	5	20	1											20	1		6	SPARE
SPACE ONLY	7		1												1		8	SPACE ONLY
SPACE ONLY	9		1												1		10	SPACE ONLY
SPACE ONLY	11		1												1		12	SPACE ONLY
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
SPACE ONLY	25		1												1		26	SPACE ONLY
SPACE ONLY	27		1												1		28	SPACE ONLY
SPACE ONLY	29		1												1		30	SPACE ONLY
SPACE ONLY	31		1												1		32	SPACE ONLY
SPACE ONLY	33		1												1		34	SPACE ONLY
SPACE ONLY	35		1												1		36	SPACE ONLY
SPACE ONLY	37		1												1		38	SPACE ONLY
SPACE ONLY	39		1												1		40	SPACE ONLY
SPACE ONLY	41		1												1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0	0	0	0	0	0	0	0	0					

PANELBOARD SCHEDULE

Panel N22C

Service 3 Phase 4 Wire

☒ 208Y/120V

☐ 480Y/277V

Main Bkr. - A - P

Lugs Only 200 A

2873 AIC Minimum

☒ Surface mounted panel

☒ 200% Neutral Bar

Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
C203/LGTS	1	20	1		3.0									20	1		2	SPARE
A249/LGTS	3	20	1			2.0								20	1		4	SPARE
SPARE	5	20	1											20	1		6	SPARE
SPARE	7	20	1												1		8	SPACE ONLY
SPARE	9	20	1												1		10	SPACE ONLY
SPARE	11	20	1												1		12	SPACE ONLY
SPACE ONLY	13		1												1		14	SPACE ONLY
SPACE ONLY	15		1												1		16	SPACE ONLY
SPACE ONLY	17		1												1		18	SPACE ONLY
SPACE ONLY	19		1												1		20	SPACE ONLY
SPACE ONLY	21		1												1		22	SPACE ONLY
SPACE ONLY	23		1												1		24	SPACE ONLY
SPACE ONLY	25		1												1		26	SPACE ONLY
SPACE ONLY	27		1												1		28	SPACE ONLY
SPACE ONLY	29		1												1		30	SPACE ONLY
SPACE ONLY	31		1												1		32	SPACE ONLY
SPACE ONLY	33		1												1		34	SPACE ONLY
SPACE ONLY	35		1												1		36	SPACE ONLY
SPACE ONLY	37		1												1		38	SPACE ONLY
SPACE ONLY	39		1												1		40	SPACE ONLY
SPACE ONLY	41		1												1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					3.0	2.0	0	0	0	0	0	0	0					

N22A

N22B

N22C

SHERLOCK, SMITH & ADAMS, INC.
ARCHITECTS - ENGINEERS
MONTGOMERY, ALABAMA

U.S. NAVAL STATION ROOSEVELT ROADS, P.R.

REPAIRS TO NAVAL HOSPITAL

208V PANELBOARDS - NORMAL SYSTEM

CONSTR. CONTR. NO XXXXX | SPECIFICATION NO XXXXX | NAVFAC DRWG NO. XXXXX | IF NO XXXXX | SHEET ? OF ??

SEAL AREA

DWG. OK FOR:

DATE:

SATISFACTORY TO:

DATE:

DESIGN BY: SWA

DRAWN BY: DBM

CHK BY: RES

APPROVED:

REVISION DESCRIPTION

DATE

NAVAL FACILITIES ENGINEERING COMMAND

DEPARTMENT OF THE NAVY

NAVY PUBLIC WORKS CENTER, JACKSONVILLE, FL

U.S. NAVAL STATION ROOSEVELT ROADS, P.R.

REPAIRS TO NAVAL HOSPITAL

208V PANELBOARDS - NORMAL SYSTEM

CONTR. CONTR. NO. XXXXX | NAVFAC DWG. NO. XXXXX | PWC DWG. NO. XXXXX

PLATE NO

EP9-41

PANELBOARD SCHEDULE

Panel C2BA
Service 3 Phase 4 Wire
☒ 208Y/120V
☐ 480Y/277V

Main Bkr. - A - P
Lugs Only 200 A
4940 AIC Minimum
☒ Surface mounted panel
☒ 200% Neutral Bar
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
SPARE	1	20	1		-			-			-			20	1		2	SPARE
SPARE	3	20	1		-			-			-			20	1		4	SPARE
SPARE	5	20	1		-			-			-			20	1		6	SPARE
SPACE ONLY	7	-	1		-			-			-			-	1		8	SPACE ONLY
SPACE ONLY	9	-	1		-			-			-			-	1		10	SPACE ONLY
SPACE ONLY	11	-	1		-			-			-			-	1		12	SPACE ONLY
SPACE ONLY	13	-	1		-			-			-			-	1		14	SPACE ONLY
SPACE ONLY	15	-	1		-			-			-			-	1		16	SPACE ONLY
SPACE ONLY	17	-	1		-			-			-			-	1		18	SPACE ONLY
SPACE ONLY	19	-	1		-			-			-			-	1		20	SPACE ONLY
SPACE ONLY	21	-	1		-			-			-			-	1		22	SPACE ONLY
SPACE ONLY	23	-	1		-			-			-			-	1		24	SPACE ONLY
SPACE ONLY	25	-	1		-			-			-			-	1		26	SPACE ONLY
SPACE ONLY	27	-	1		-			-			-			-	1		28	SPACE ONLY
SPACE ONLY	29	-	1		-			-			-			-	1		30	SPACE ONLY
SPACE ONLY	31	-	1		-			-			-			-	1		32	SPACE ONLY
SPACE ONLY	33	-	1		-			-			-			-	1		34	SPACE ONLY
SPACE ONLY	35	-	1		-			-			-			-	1		36	SPACE ONLY
SPACE ONLY	37	-	1		-			-			-			-	1		38	SPACE ONLY
SPACE ONLY	39	-	1		-			-			-			-	1		40	SPACE ONLY
SPACE ONLY	41	-	1		-			-			-			-	1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					

PANELBOARD SCHEDULE

Panel C2BB
Service 3 Phase 4 Wire
☒ 208Y/120V
☐ 480Y/277V

Main Bkr. - A - P
Lugs Only 200 A
4742 AIC Minimum
☒ Surface mounted panel
☒ 200% Neutral Bar
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
SPARE	1	20			-			-			-			20	1		2	SPARE
SPARE	3	20	1		-			-			-			20	1		4	SPARE
SPARE	5	20	1		-			-			-			20	1		6	SPARE
SPACE ONLY	7	-	1		-			-			-			-	1		8	SPACE ONLY
SPACE ONLY	9	-	1		-			-			-			-	1		10	SPACE ONLY
SPACE ONLY	11	-	1		-			-			-			-	1		12	SPACE ONLY
SPACE ONLY	13	-	1		-			-			-			-	1		14	SPACE ONLY
SPACE ONLY	15	-	1		-			-			-			-	1		16	SPACE ONLY
SPACE ONLY	17	-	1		-			-			-			-	1		18	SPACE ONLY
SPACE ONLY	19	-	1		-			-			-			-	1		20	SPACE ONLY
SPACE ONLY	21	-	1		-			-			-			-	1		22	SPACE ONLY
SPACE ONLY	23	-	1		-			-			-			-	1		24	SPACE ONLY
SPACE ONLY	25	-	1		-			-			-			-	1		26	SPACE ONLY
SPACE ONLY	27	-	1		-			-			-			-	1		28	SPACE ONLY
SPACE ONLY	29	-	1		-			-			-			-	1		30	SPACE ONLY
SPACE ONLY	31	-	1		-			-			-			-	1		32	SPACE ONLY
SPACE ONLY	33	-	1		-			-			-			-	1		34	SPACE ONLY
SPACE ONLY	35	-	1		-			-			-			-	1		36	SPACE ONLY
SPACE ONLY	37	-	1		-			-			-			-	1		38	SPACE ONLY
SPACE ONLY	39	-	1		-			-			-			-	1		40	SPACE ONLY
SPACE ONLY	41	-	1		-			-			-			-	1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					

PANELBOARD SCHEDULE

Panel C21A
Service 3 Phase 4 Wire
☒ 208Y/120V
☐ 480Y/277V

Main Bkr. - A - P
Lugs Only 200 A
4940 AIC Minimum
☒ Surface mounted panel
☒ 200% Neutral Bar
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
SPARE	1	20			-			-			-			20	1		2	SPARE
SPARE	3	20			-			-			-			20	1		4	SPARE
SPARE	5	20			-			-			-			20	1		6	SPARE
SPACE ONLY	7	-	1		-			-			-			-	1		8	SPACE ONLY
SPACE ONLY	9	-	1		-			-			-			-	1		10	SPACE ONLY
SPACE ONLY	11	-	1		-			-			-			-	1		12	SPACE ONLY
SPACE ONLY	13	-	1		-			-			-			-	1		14	SPACE ONLY
SPACE ONLY	15	-	1		-			-			-			-	1		16	SPACE ONLY
SPACE ONLY	17	-	1		-			-			-			-	1		18	SPACE ONLY
SPACE ONLY	19	-	1		-			-			-			-	1		20	SPACE ONLY
SPACE ONLY	21	-	1		-			-			-			-	1		22	SPACE ONLY
SPACE ONLY	23	-	1		-			-			-			-	1		24	SPACE ONLY
SPACE ONLY	25	-	1		-			-			-			-	1		26	SPACE ONLY
SPACE ONLY	27	-	1		-			-			-			-	1		28	SPACE ONLY
SPACE ONLY	29	-	1		-			-			-			-	1		30	SPACE ONLY
SPACE ONLY	31	-	1		-			-			-			-	1		32	SPACE ONLY
SPACE ONLY	33	-	1		-			-			-			-	1		34	SPACE ONLY
SPACE ONLY	35	-	1		-			-			-			-	1		36	SPACE ONLY
SPACE ONLY	37	-	1		-			-			-			-	1		38	SPACE ONLY
SPACE ONLY	39	-	1		-			-			-			-	1		40	SPACE ONLY
SPACE ONLY	41	-	1		-			-			-			-	1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					

PANELBOARD SCHEDULE

Panel C21B
Service 3 Phase 4 Wire
☒ 208Y/120V
☐ 480Y/277V

Main Bkr. - A - P
Lugs Only 200 A
472a AIC Minimum
☒ Surface mounted panel
☒ 200% Neutral Bar
Remarks
-

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
SPARE	1	20	1		-			-			-			20	1		2	SPARE
SPARE	3	20	1		-			-			-			20	1		4	SPARE
SPARE	5	20	1		-			-			-			20	1		6	SPARE
SPACE ONLY	7	-			-			-			-			-	1		8	SPACE ONLY
SPACE ONLY	9	-	1		-			-			-			-	1		10	SPACE ONLY
SPACE ONLY	11	-	1		-			-			-			-	1		12	SPACE ONLY
SPACE ONLY	13	-	1		-			-			-			-	1		14	SPACE ONLY
SPACE ONLY	15	-	1		-			-			-			-	1		16	SPACE ONLY
SPACE ONLY	17	-	1		-			-			-			-	1		18	SPACE ONLY
SPACE ONLY	19	-	1		-			-			-			-	1		20	SPACE ONLY
SPACE ONLY	21	-	1		-			-			-			-	1		22	SPACE ONLY
SPACE ONLY	23	-	1		-			-			-			-	1		24	SPACE ONLY
SPACE ONLY	25	-	1		-			-			-			-	1		26	SPACE ONLY
SPACE ONLY	27	-	1		-			-			-			-	1		28	SPACE ONLY
SPACE ONLY	29	-	1		-			-			-			-	1		30	SPACE ONLY
SPACE ONLY	31	-	1		-			-			-			-	1		32	SPACE ONLY
SPACE ONLY	33	-	1		-			-			-			-	1		34	SPACE ONLY
SPACE ONLY	35	-	1		-			-			-			-	1		36	SPACE ONLY
SPACE ONLY	37	-	1		-			-			-			-	1		38	SPACE ONLY
SPACE ONLY	39	-	1		-			-			-			-	1		40	SPACE ONLY
SPACE ONLY	41	-	1		-			-			-			-	1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					

PANELBOARD SCHEDULE

Panel C21C
Service 3 Phase 4 Wire
☒ 208Y/120V
☐ 480Y/277V

Main Bkr. - A - P
Lugs Only 200 A
2275 AIC Minimum
☒ Surface mounted panel
☒ 200% Neutral Bar
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
SPARE	1	20			-			-			-			20	1		2	SPARE
SPARE	3	20			-			-			-			20	1		4	SPARE
SPARE	5	20	1		-			-			-			20	1		6	SPARE
SPACE ONLY	7	-	1		-			-			-			-	1		8	SPACE ONLY
SPACE ONLY	9	-	1		-			-			-			-	1		10	SPACE ONLY
SPACE ONLY	11	-	1		-			-			-			-	1		12	SPACE ONLY
SPACE ONLY	13	-	1		-			-			-			-	1		14	SPACE ONLY
SPACE ONLY	15	-	1		-			-			-			-	1		16	SPACE ONLY
SPACE ONLY	17	-	1		-			-			-			-	1		18	SPACE ONLY
SPACE ONLY	19	-	1		-			-			-			-	1		20	SPACE ONLY
SPACE ONLY	21	-	1		-			-			-			-	1		22	SPACE ONLY
SPACE ONLY	23	-	1		-			-			-			-	1		24	SPACE ONLY
SPACE ONLY	25	-	1		-			-			-			-	1		26	SPACE ONLY
SPACE ONLY	27	-	1		-			-			-			-	1		28	SPACE ONLY
SPACE ONLY	29	-	1		-			-			-			-	1		30	SPACE ONLY
SPACE ONLY	31	-	1		-			-			-			-	1		32	SPACE ONLY
SPACE ONLY	33	-	1		-			-			-			-	1		34	SPACE ONLY
SPACE ONLY	35	-	1		-			-			-			-	1		36	SPACE ONLY
SPACE ONLY	37	-	1		-			-			-			-	1		38	SPACE ONLY
SPACE ONLY	39	-	1		-			-			-			-	1		40	SPACE ONLY
SPACE ONLY	41	-	1		-			-			-			-	1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					

C2BA C21B
C2BB C21C
C21A

SHERLOCK, SMITH & ADAMS, INC.
ARCHITECTS – ENGINEERS
MONTGOMERY, ALABAMA

U.S. NAVAL STATION ROOSEVELT ROADS, P.R.
REPAIRS TO NAVAL HOSPITAL
280V PANELBOARDS – CRITICAL BRANCH

CONSTR. CONTR. NO XXXXX | SPECIFICATION NO. XXXXX | NAVFAC DRWG. NO. XXXXX | TF NO XXXXX | SHEET ? OF ??

SEAL AREA

DSG. DR. DR. | DATE | SATISFACTORY TO: | DATE | DESIGN BY: SWA | DRAWN BY: CBN | CHK. BY: RES

REVISION DESCRIPTION | DATE

NAVAL FACILITIES ENGINEERING COMMAND
DEPARTMENT OF THE NAVY
NAVY PUBLIC WORKS CENTER, JACKSONVILLE, FL
U.S. NAVAL STATION ROOSEVELT ROADS, P.R.
REPAIRS TO NAVAL HOSPITAL
280V PANELBOARDS – CRITICAL BRANCH

CONSTR. CONTR. NO XXXXX | NAVFAC DRWG NO XXXXX | PWC DWG NO XXXXX

PLATE NO
EP9-50

PANELBOARD SCHEDULE

Panel C22A
Service 3 Phase 4 Wire
☒ 208Y/120V
☐ 480Y/277V

Main Bkr. - A - P
Lugs Only 200 A
4902 AIC Minimum
☒ Surface mounted panel
☒ 200% Neutral Bar
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING φA	LIGHTING φB	LIGHTING φC	GEN. RECEPT. φA	GEN. RECEPT. φB	GEN. RECEPT. φC	SPECIAL φA	SPECIAL φB	SPECIAL φC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
SPACE ONLY	1													-	1		2	SPACE ONLY
SPACE ONLY	3		1											-	1		4	SPACE ONLY
SPACE ONLY	5		1											-	1		6	SPACE ONLY
SPACE ONLY	7		1											20	1		8	A253/BL
SPACE ONLY	9		1						6.0					20	1		10	A220/REC
SPACE ONLY	11		1							6.0				20	1		12	A208, A219/REC
A230/REC	13	20	1		-			6.0						20	1		14	A212/REC
A230/REC	15	20	1		-			6.0	6.0					20	1		16	A213/REC
A221/REC	17	20	1							6.0				20	1		18	A213/REC
A223/REC	19	20	1		-			3.0		6.0				20	1		20	A241, A243/REC
A225/REC	21	20	1					9.0	6.0					20	1		22	A243, A244/REC
A225/REC	23	20	1						9.0	6.0				20	1		24	A255/REC
A255, A258/REC	25	20	1		-			9.0						20	1		26	SPARE
SPARE	27	20	1											20	1		28	SPARE
SPARE	29	20	1											20	1		30	SPARE
SPACE ONLY	31		1											-	1		32	SPACE ONLY
SPACE ONLY	33		1											-	1		34	SPACE ONLY
SPACE ONLY	35		1											-	1		36	SPACE ONLY
SPACE ONLY	37		1											-	1		38	SPACE ONLY
SPACE ONLY	39		1											-	1		40	SPACE ONLY
SPACE ONLY	41		1											-	1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					-	-	-	33	33	30	0	0	0					

PANELBOARD SCHEDULE

Panel C22B
Service 3 Phase 4 Wire
☒ 208Y/120V
☐ 480Y/277V

Main Bkr. - A - P
Lugs Only 200 A
4707 AIC Minimum
☒ Surface mounted panel
☒ 200% Neutral Bar
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING φA	LIGHTING φB	LIGHTING φC	GEN. RECEPT. φA	GEN. RECEPT. φB	GEN. RECEPT. φC	SPECIAL φA	SPECIAL φB	SPECIAL φC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
B207/RECEPTACLES	1	20	1		-		-	6.0			-			20	1		2	B216/RECEPTACLES
B207/RECEPTACLES	3	20	1		-		-	6.0	6.0					20	1		4	B225/RECEPTACLES
B215/RECEPTACLES	5	20	1						6.0	6.0				20	1		6	B225/RECEPTACLES
B226/RECEPTACLES	7	20	1		-		-	6.0			-			20	1		8	B236/RECEPTACLES
B226/RECEPTACLES	9	20	1		-		-	6.0	6.0					20	1		10	B237/RECEPTACLES
B236/RECEPTACLES	11	20	1						6.0	6.0				20	1		12	B237/RECEPTACLES
B204/RECEPTACLES	13	20	1		-		-	6.0						20	1		14	B213/RECEPTACLES
B212/RECEPTACLES	15	20	1		-		-	6.0	6.0					20	1		16	B219/RECEPTACLES
B212/RECEPTACLES	17	20	1						6.0	6.0				20	1		18	B220/RECEPTACLES
B220/RECEPTACLES	19	20	1		-		-	6.0						20	1		20	B242/RECEPTACLES
B229/RECEPTACLES	21	20	1		-		-	6.0	6.0					20	1		22	B243/RECEPTACLES
B230/RECEPTACLES	23	20	1		-		-		6.0	6.0				20	1		24	0222,34/REC
SPARE	25	20	1		-		-							20	1		26	SPARE
SPARE	27	20	1											20	1		28	SPARE
SPARE	29	20	1											20	1		30	SPARE
SPACE ONLY	31	-	1		-		-							20	1		32	SPARE
SPACE ONLY	33	-	1		-		-		0					20	1		34	SPARE
SPACE ONLY	35	-	1		-		-							20	1		36	SPACE ONLY
SPACE ONLY	37	-	1		-		-							20	1		38	SPACE ONLY
SPACE ONLY	39	-	1		-		-							20	1		40	SPACE ONLY
SPACE ONLY	41	-	1		-		-							20	1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					21.4	19.2	16	48	48	51	0	0	0					

PANELBOARD SCHEDULE

Panel C22C
Service - Phase - Wire
☒ 208Y/120V
☐ 480Y/277V

Main Bkr. - A - P
Lugs Only 200 A
2361 AIC Minimum
☒ Surface mounted panel
☒ 200% Neutral Bar
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING φA	LIGHTING φB	LIGHTING φC	GEN. RECEPT. φA	GEN. RECEPT. φB	GEN. RECEPT. φC	SPECIAL φA	SPECIAL φB	SPECIAL φC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
C246/RECEPTACLES	1	20	1		-			6			-			20	1		2	C236/RECEPTACLES
C241/RECEPTACLES	3	20	1				-		6					20	1		4	C231/RECEPTACLES
C241/RECEPTACLES	5	20	1				-			6				20	1		6	SPARE
C231/RECEPTACLES	7	20	1		-			6			-			20	1		8	SPARE
C230/RECEPTACLES	9	20	1		6.4		-		6					20	1		10	SPARE
D240/RECEPTACLES	11	20	1			6.4	5.4							20	1		12	SPARE
D236, D240/RECEPTACLES	13	20	1		-		4.3	8.4							1		14	SPARE
SPARE	15	20	1		-				6.0					-	1		16	SPARE
SPARE	17	20	1		-									-	1		18	SPACE ONLY
SPARE	19	20	1		-									-	1		20	SPACE ONLY
SPARE	21	20	1											-	1		22	SPACE ONLY
SPACE ONLY	23	-	1											-	1		24	SPACE ONLY
SPACE ONLY	25	-	1		-									-	1		26	SPACE ONLY
SPACE ONLY	27	-	1		-									-	1		28	SPACE ONLY
SPACE ONLY	29	-	1		-									-	1		30	SPACE ONLY
SPACE ONLY	31	-	1		-									-	1		32	SPACE ONLY
SPACE ONLY	33	-	1		-									-	1		34	SPACE ONLY
SPACE ONLY	35	-	1		-									-	1		36	SPACE ONLY
SPACE ONLY	37	-	1		-									-	1		38	SPACE ONLY
SPACE ONLY	39	-	1		-									-	1		40	SPACE ONLY
SPACE ONLY	41	-	1		-									-	1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					6.4	6.4	9.7	24.0	36.0	12.0	0	0	0					

C22A

C22B

C22C

SHERLOCK, SMITH & ADAMS, INC.
ARCHITECTS - ENGINEERS
MONTGOMERY, ALABAMA

U.S. NAVAL STATION ROOSEVELT ROADS, P.R.
REPAIRS TO NAVAL HOSPITAL
208V PANELBOARDS - CRITICAL BRANCH

CONSTR. CONTR. NO. XXXXX | SPECIFICATION NO. XXXXX | NAVFAC DRWG. NO. XXXXX | TF NO XXXXX | SHEET ? OF ??

SEAL AREA

DIC. OK. DIC. | DATE | SATISFACTORY TO | DATE:

DESIGN BY SWA | DRAWN BY CBN | CHK. BY RFS | APPROVED:

REVISION DESCRIPTION | DATE

NAVAL FACILITIES ENGINEERING COMMAND
DEPARTMENT OF THE NAVY
NAVY PUBLIC WORKS CENTER, JACKSONVILLE, FL
U.S. NAVAL STATION ROOSEVELT ROADS, P.R.
REPAIRS TO NAVAL HOSPITAL
208V PANELBOARDS - CRITICAL BRANCH

PLATE NO

EP9-51

PANELBOARD SCHEDULE

Panel L2BD
Service 3 Phase 4 Wire
☒ 208Y/120V
☐ 480Y/277V
Main Bkr. - A - P
Lugs Only 100 A
2620 AIC Minimum
☒ Surface mounted panel
Remarks
-

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
D02, D03, D04,/LGTS	1	20	1		10.0			-			-			20	1		1	SPARE
MAIN FIRE ALARM CONTROL PANEL	3	20	1		-			-			-	10.0		20	1		4	SPARE
SPARE	5	20	1		-			-			-			20	1		6	SPARE
SPARE	7	20	1		-			-			-			-	1		8	SPACE ONLY
SPARE	9	20	1		-			-			-			-	1		10	SPACE ONLY
SPARE	11	20	1		-			-			-			-	1		12	SPACE ONLY
SPACE ONLY	13	-	1		-			-			-			-	1		14	SPACE ONLY
SPACE ONLY	15	-	1		-			-			-			-	1		16	SPACE ONLY
SPACE ONLY	17	-	1		-			-			-			-	1		18	SPACE ONLY
SPACE ONLY	19	-	1		-			-			-			-	1		20	SPACE ONLY
SPACE ONLY	21	-	1		-			-			-			-	1		22	SPACE ONLY
SPACE ONLY	23	-	1		-			-			-			-	1		24	SPACE ONLY
SPACE ONLY	25	-	1		-			-			-			-	1		26	SPACE ONLY
SPACE ONLY	27	-	1		-			-			-			-	1		28	SPACE ONLY
SPACE ONLY	29	-	1		-			-			-			-	1		30	SPACE ONLY
SPACE ONLY	31	-	1		-			-			-			-	1		32	SPACE ONLY
SPACE ONLY	33	-	1		-			-			-			-	1		34	SPACE ONLY
SPACE ONLY	35	-	1		-			-			-			-	1		36	SPACE ONLY
SPACE ONLY	37	-	1		-			-			-			-	1		38	SPACE ONLY
SPACE ONLY	39	-	1		-			-			-			-	1		40	SPACE ONLY
SPACE ONLY	41	-	1		-			-			-			-	1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					10.0	0.00	0.00	0.00	0.00	0.00	0.00	10.0	0.00					

PANELBOARD SCHEDULE

Panel L21D
Service 3 Phase 4 Wire
☒ 208Y/120V
☐ 480Y/277V
Main Bkr. - A - P
Lugs Only 100 A
1921 AIC Minimum
☒ Surface mounted panel
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
SPARE	1	20	1		-			-			-			20	1		1	SPARE
SPARE	3	20	1		-			-			-			20	1		4	SPARE
SPARE	5	20	1		-			-			-			20	1		6	SPARE
SPACE ONLY	7	-	1		-			-			-			-	1		8	SPACE ONLY
SPACE ONLY	9	-	1		-			-			-			-	1		10	SPACE ONLY
SPACE ONLY	11	-	1		-			-			-			-	1		12	SPACE ONLY
SPACE ONLY	13	-	1		-			-			-			-	1		14	SPACE ONLY
SPACE ONLY	15	-	1		-			-			-			-	1		16	SPACE ONLY
SPACE ONLY	17	-	1		-			-			-			-	1		18	SPACE ONLY
SPACE ONLY	19	-	1		-			-			-			-	1		20	SPACE ONLY
SPACE ONLY	21	-	1		-			-			-			-	1		22	SPACE ONLY
SPACE ONLY	23	-	1		-			-			-			-	1		24	SPACE ONLY
SPACE ONLY	25	-	1		-			-			-			-	1		26	SPACE ONLY
SPACE ONLY	27	-	1		-			-			-			-	1		28	SPACE ONLY
SPACE ONLY	29	-	1		-			-			-			-	1		30	SPACE ONLY
SPACE ONLY	31	-	1		-			-			-			-	1		32	SPACE ONLY
SPACE ONLY	33	-	1		-			-			-			-	1		34	SPACE ONLY
SPACE ONLY	35	-	1		-			-			-			-	1		36	SPACE ONLY
SPACE ONLY	37	-	1		-			-			-			-	1		38	SPACE ONLY
SPACE ONLY	39	-	1		-			-			-			-	1		40	SPACE ONLY
SPACE ONLY	41	-	1		-			-			-			-	1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					

PANELBOARD SCHEDULE

Panel L22C
Service 3 Phase 4 Wire
☒ 208Y/120V
☐ 480Y/277V
Main Bkr. - A - P
Lugs Only 100 A
2170 AIC Minimum
☒ Surface mounted panel
Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
C203/LGTS	1	20	1		2.00			-			-			20	1		1	SPARE
249/LGTS	3	20	1		-	1.00		-			-			20	1		4	SPARE
SPARE	5	20	1			-		-			-			20	1		6	SPARE
SPARE	7	20	1		-			-			-			-	1		8	SPACE ONLY
SPARE	9	20	1		-			-			-			-	1		10	SPACE ONLY
SPARE	11	20	1		-			-			-			-	1		12	SPACE ONLY
SPACE ONLY	13	-	1		-			-			-			-	1		14	SPACE ONLY
SPACE ONLY	15	-	1		-			-			-			-	1		16	SPACE ONLY
SPACE ONLY	17	-	1		-			-			-			-	1		18	SPACE ONLY
SPACE ONLY	19	-	1		-			-			-			-	1		20	SPACE ONLY
SPACE ONLY	21	-	1		-			-			-			-	1		22	SPACE ONLY
SPACE ONLY	23	-	1		-			-			-			-	1		24	SPACE ONLY
SPACE ONLY	25	-	1		-			-			-			-	1		26	SPACE ONLY
SPACE ONLY	27	-	1		-			-			-			-	1		28	SPACE ONLY
SPACE ONLY	29	-	1		-			-			-			-	1		30	SPACE ONLY
SPACE ONLY	31	-	1		-			-			-			-	1		32	SPACE ONLY
SPACE ONLY	33	-	1		-			-			-			-	1		34	SPACE ONLY
SPACE ONLY	35	-	1		-			-			-			-	1		36	SPACE ONLY
SPACE ONLY	37	-	1		-			-			-			-	1		38	SPACE ONLY
SPACE ONLY	39	-	1		-			-			-			-	-		40	SPACE ONLY
SPACE ONLY	41	-	1		-			-			-			-	-		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					2.00	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					

PANELBOARD SCHEDULE

Panel L2G
Service 3 Phase 4 Wire
☒ 208Y/120V
☐ 480Y/277V
Main Bkr. - A - P
Lugs Only 100 A
1377 AIC Minimum
☒ Surface mounted panel
Remarks
-

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING 0A	LIGHTING 0B	LIGHTING 0C	GEN. RECEPT. 0A	GEN. RECEPT. 0B	GEN. RECEPT. 0C	SPECIAL 0A	SPECIAL 0B	SPECIAL 0C	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
OCP-CW SYSTEM PANEL	1	20	1		-			-			3.00			20	1		2	SPARE
BATTERY CHARGER - #1	3	20	1		-			-				3.00		20	1		4	SPARE
LEVEL DETECTION SYSTEM	5	20	1		-			-			-		3.00	20	1		6	BATTERY CHARGER #2
A0102/REC	7	20	1		-			7.50			-		3.00	20	1		8	A0103 EXHAUST FAN
A0103/REC	9	20	1		-			-	9.00		-		-	20	1		10	A0104 EXHAUST FAN
A0104,A0105/REC	11	20	1		-			-		10.5			-	20	1		12	A0105 EXHAUST FAN
PRE-LUBE OIL PUMP	13	20	1		-			-			7.00			20	1		14	SPARE
PRE-LUBE OIL PUMP	15	20	1		-			-			-	2.00		20	1		16	SPARE
SPARE	17	20	1		-			-			-		-	20	1		18	SPARE
SPARE	19	20	1		-			-			-		-	20	1		20	SPARE
SPARE	21	20	1		-			-			-		-	20	1		22	SPARE
SPARE	23	20	1		-			-			-		-	20	1		24	SPARE
SPACE ONLY	25	-	1		-			-			-		-	-	1		26	SPACE ONLY
SPACE ONLY	27	-	1		-			-			-		-	-	1		28	SPACE ONLY
SPACE ONLY	29	-	1		-			-			-		-	-	1		30	SPACE ONLY
SPACE ONLY	31	-	1		-			-			-		-	-	1		32	SPACE ONLY
SPACE ONLY	33	-	1		-			-			-		-	-	1		34	SPACE ONLY
SPACE ONLY	35	-	1		-			-			-		-	-	1		36	SPACE ONLY
SPACE ONLY	37	-	1		-			-			-		-	-	1		38	SPACE ONLY
SPACE ONLY	39	-	1		-			-			-		-	-	1		40	SPACE ONLY
SPACE ONLY	41	-	1		-			-			-		-	-	1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.00	0.00	0.00	7.50	9.00	10.5	5.0	5.0	6.00					

L2BD L2G
L21D
L22C

SHERLOCK, SMITH & ADAMS, INC.
ARCHITECTS – ENGINEERS
MONTGOMERY, ALABAMA

U.S. NAVAL STATION ROOSEVELT ROADS, P.R.
REPAIRS TO NAVAL HOSPITAL
208V PANELBOARDS – LIFE SAFETY BRANCH

CONSTR. CONTR NO.	SPECIFICATION NO.	NAVFAC DRWG. NO.	TF NO XXXXX
XXXXX	XXXXX	XXXXX	SHEET ? OF ??

SEAL AREA

REVISION DESCRIPTION
DWG. CH. DR.
DATE
SATISFACTORY TO
DATE
DATE

DESIGN BY SW/A
DRAWN BY CBN
CHK. BY RES
APPROVED:

NAVAL FACILITIES ENGINEERING COMMAND
DEPARTMENT OF THE NAVY
NAVY PUBLIC WORKS CENTER, JACKSONVILLE, FL
U.S. NAVAL STATION ROOSEVELT ROADS, P.R.
REPAIRS TO NAVAL HOSPITAL
208V PANELBOARDS – LIFE SAFETY BRANCH
CONSTR. CONTR. NO. XXXXX
NAVFAC DWG. NO. XXXXX
NAVFAC DWG. NO. XXXXX

PLATE NO.
EP9-60

PANELBOARD SCHEDULE

Panel Q2BD

Service 3 Phase 4 Wire

☒ 208Y/120V

☐ 480Y/277V

Main Bkr. - A - P

Lugs Only 100 A

4517 AIC Minimum

☒ Surface mounted panel

Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING GA	LIGHTING GB	LIGHTING GC	GEN. RECEPT. GA	GEN. RECEPT. GB	GEN. RECEPT. GC	SPECIAL GA	SPECIAL GB	SPECIAL GC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
SPARE	1	20	1		–			–			–			20	1		1	SPARE
SPARE	3	20	1		–			–			–			20	1		4	SPARE
SB4/DDC CONTROL PANEL	5	20	1		–			–			–		5.0	20	1		6	SPARE
SD1/DDC CONTROL PANEL	7	20	1		–			–			5.0		–	–	1		8	SPACE ONLY
SPARE	9	20	1		–			–			–		–	–	1		10	SPACE ONLY
SPACE ONLY	11	–	1		–			–			–		–	–	1		12	SPACE ONLY
SPACE ONLY	13	–	1		–			–			–		–	–	1		14	SPACE ONLY
SPACE ONLY	15	–	1		–			–			–		–	–	1		16	SPACE ONLY
SPACE ONLY	17	–	1		–			–			–		–	–	1		18	SPACE ONLY
SPACE ONLY	19	–	1		–			–			–		–	–	1		20	SPACE ONLY
SPACE ONLY	21	–	1		–			–			–		–	–	1		22	SPACE ONLY
SPACE ONLY	23	–	1		–			–			–		–	–	1		24	SPACE ONLY
SPACE ONLY	25	–	1		–			–			–		–	–	1		26	SPACE ONLY
SPACE ONLY	27	–	1		–			–			–		–	–	1		28	SPACE ONLY
SPACE ONLY	29	–	1		–			–			–		–	–	1		30	SPACE ONLY
SPACE ONLY	31	–	1		–			–			–		–	–	1		32	SPACE ONLY
SPACE ONLY	33	–	1		–			–			–		–	–	1		34	SPACE ONLY
SPACE ONLY	35	–	1		–			–			–		–	–	1		36	SPACE ONLY
SPACE ONLY	37	–	1		–			–			–		–	–	1		38	SPACE ONLY
SPACE ONLY	39	–	1		–			–			–		–	–	1		40	SPACE ONLY
SPACE ONLY	41	–	1		–			–			–		–	–	1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.00	0.00	0.00	0.00	0.00	0.00	5.0	0.00	5.0					

PANELBOARD SCHEDULE

Panel Q21D

Service 3 Phase 4 Wire

☒ 208Y/120V

☐ 480Y/277V

Main Bkr. - A - P

Lugs Only 100 A

2348 AIC Minimum

☒ Surface mounted panel

Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING GA	LIGHTING GB	LIGHTING GC	GEN. RECEPT. GA	GEN. RECEPT. GB	GEN. RECEPT. GC	SPECIAL GA	SPECIAL GB	SPECIAL GC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
SPARE	1	20	1		–			–			–			20	1		1	SPARE
SPARE	3	20	1		–			–			–			20	1		4	SPARE
SPARE	5	20	1		–			–			–			20	1		6	SPARE
SPACE ONLY	7	–	1		–			–			–			–	1		8	SPACE ONLY
SPACE ONLY	9	–	1		–			–			–			–	1		10	SPACE ONLY
SPACE ONLY	11	–	1		–			–			–			–	1		12	SPACE ONLY
SPACE ONLY	13	–	1		–			–			–			–	1		14	SPACE ONLY
SPACE ONLY	15	–	1		–			–			–			–	1		16	SPACE ONLY
SPACE ONLY	17	–	1		–			–			–			–	1		18	SPACE ONLY
SPACE ONLY	19	–	1		–			–			–			–	1		20	SPACE ONLY
SPACE ONLY	21	–	1		–			–			–			–	1		22	SPACE ONLY
SPACE ONLY	23	–	1		–			–			–			–	1		24	SPACE ONLY
SPACE ONLY	25	–	1		–			–			–			–	1		26	SPACE ONLY
SPACE ONLY	27	–	1		–			–			–			–	1		28	SPACE ONLY
SPACE ONLY	29	–	1		–			–			–			–	1		30	SPACE ONLY
SPACE ONLY	31	–	1		–			–			–			–	1		32	SPACE ONLY
SPACE ONLY	33	–	1		–			–			–			–	1		34	SPACE ONLY
SPACE ONLY	35	–	1		–			–			–			–	1		36	SPACE ONLY
SPACE ONLY	37	–	1		–			–			–			–	1		38	SPACE ONLY
SPACE ONLY	39	–	1		–			–			–			–	1		40	SPACE ONLY
SPACE ONLY	41	–	1		–			–			–			–	1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					

PANELBOARD SCHEDULE

Panel Q22C

Service 3 Phase 4 Wire

☒ 208Y/120V

☐ 480Y/277V

Main Bkr. - A - P

Lugs Only 100 A

3239 AIC Minimum

☒ Surface mounted panel

Remarks

ROOM NOS / REMARKS	CIR. NO.	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	LIGHTING GA	LIGHTING GB	LIGHTING GC	GEN. RECEPT. GA	GEN. RECEPT. GB	GEN. RECEPT. GC	SPECIAL GA	SPECIAL GB	SPECIAL GC	BREAKERS AMPS	BREAKERS POLES	H.P. OR K.W.	CIR. NO.	ROOM NOS / REMARKS
EF-3D2	1	20	1		–			–			6.00			20	1		1	EF-3B1
EF-3D3	3	20	1		–			–			6.00			–	1		4	EF-3A2
EF-3B4	5	20	1		–			–			–	6.00		20	1		6	EF-3A1
DCP-AHU-3A	7	20	1		–			–			5.00	6.00		20	1		8	SPARE
DCP-AHU-3B	9	20	1		–			–			–	5.00		20	1		10	SPARE
SPARE	11	20	1		–			–			–	–		–	1		12	SPARE
SPARE	13	20	1		–			–			–	–		–	1		14	SPACE ONLY
SPARE	15	20	1		–			–			–	–		–	1		16	SPACE ONLY
SPARE	17	20	1		–			–			–	–		–	1		18	SPACE ONLY
SPACE ONLY	19	–	1		–			–			–	–		–	1		20	SPACE ONLY
SPACE ONLY	21	–	1		–			–			–	–		–	1		22	SPACE ONLY
SPACE ONLY	23	–	1		–			–			–	–		–	1		24	SPACE ONLY
SPACE ONLY	25	–	1		–			–			–	–		–	1		26	SPACE ONLY
SPACE ONLY	27	–	1		–			–			–	–		–	1		28	SPACE ONLY
SPACE ONLY	29	–	1		–			–			–	–		–	1		30	SPACE ONLY
SPACE ONLY	31	–	1		–			–			–	–		–	1		32	SPACE ONLY
SPACE ONLY	33	–	1		–			–			–	–		–	1		34	SPACE ONLY
SPACE ONLY	35	–	1		–			–			–	–		–	1		36	SPACE ONLY
SPACE ONLY	37	–	1		–			–			–	–		–	1		38	SPACE ONLY
SPACE ONLY	39	–	1		–			–			–	–		–	1		40	SPACE ONLY
SPACE ONLY	41	–	1		–			–			–	–		–	1		42	SPACE ONLY
TOTAL CONNECTED LOAD (AMPS)					0.00	0.00	0.00	0.00	0.00	0.00	17.0	17.0	12.0					

Q2BD

Q21D

Q22C

SHERLOCK, SMITH & ADAMS, INC.
ARCHITECTS - ENGINEERS
MONTGOMERY, ALABAMA

U.S. NAVAL STATION ROOSEVELT ROADS, P.R.
REPAIRS TO NAVAL HOSPITAL
208V PANELBOARDS - EQUIPMENT BRANCH

CONSTR. CONTR. NO. XXXXX | SPECIFICATION NO. XXXXX | NAVFAC DRWG. NO. XXXXX | IF NO XXXXX | SHEET ? OF ??

DEPARTMENT OF THE NAVY
NAVY PUBLIC WORKS CENTER, JACKSONVILLE, FL

U.S. NAVAL STATION ROOSEVELT ROADS, P.R.
REPAIRS TO NAVAL HOSPITAL
208V PANELBOARDS - EQUIPMENT BRANCH

NAVAL FACILITIES ENGINEERING COMMAND

NAVFAC DWG. NO XXXXX | FMC DWG. NO XXXXX | CONTRACT CONTR. NO XXXXX

PLATE NO

EP9-65

DATE | REVISION DESCRIPTION | DSG. ON DRG. | DATE | SATISFACTORY TO | DATE

DESIGN BY: SWA | DRAWN BY: CBN | CHK BY: RES | APPROVED: